

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1518:103

Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Prefco Products, Inc., 2823 Route 413, Buckingham, PA 18912
Contact: Richard McNutt (215) 340-1707

DESIGN: Models 5600 ceiling dampers. Models listed below:

<i>Models</i>	<i>Shape</i>	<i>Max. Size Sq. In.</i>	<i>Length or Diameter</i>		<i>Width</i>	
			<i>Max.</i>	<i>Min.</i>	<i>Max.</i>	<i>Min.</i>
5600	Round	108	12"	5"	NA	NA
5660	Square or Rect.	108	20"	5"	22"	5"
5650	Square or Rect.	108	11"	3"	24"	3"
5610	Round	36	7"	4.5"	NA	NA
5610	Round	576	27"	6"	NA	NA
5620	Round	324	20.5"	6"	NA	NA
5670	Square or Rect.	180	11"	3"	24"	3"
5670-S	Square or Rect.	36	11"	3"	12"	3"
5671	Square or Rect.	42	12"	2.5"	12"	2.5"
5671	Round	55	8-3/8"	2.5"	NA	NA
5680	Square or Rect.	576	30"	6"	34"	6"
5680-S	Square or Rect.	36	8"	4.5"	8"	4.5"
5690	Square or Rect.	324	30"	6"	34"	6"

Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as ceiling dampers for use as a heat barrier in air handling openings penetrating fire resistive membrane ceilings. Type 5600, 5650, 5660 are intended for use in fire resistive floor or roof ceiling with restrained or unrestrained assembly rating of 2 Hr. or less. Type 5610, 5620, 5670, 5671, 5680 and 5690 are intended for use in fire resistive floor or roof ceiling with restrained or unrestrained assembly rating of 3 Hr. or less.

12-10-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 12, 2002

Listing Expires June 30, 2003

Authorized By:

**DIANE K. AREND, Senior Deputy
Program Manager**